



**Scott Walker, Governor**  
**Dave Ross, Secretary**

August 21, 2015

CUST ID No. 1327685

TONY SUSTARICH  
CHAMPION INC  
PO BOX 490  
IRON MOUNTAIN MI 49801

**CONDITIONAL APPROVAL**  
**PLAN APPROVAL EXPIRES: 08/31/2020**

Re: Description: SEWAGE TANKS, CONCRETE  
Manufacturer: CHAMPION, INC.  
Product Name: SEPTIC, HOLDING OR PUMP (trans id 2591175)  
Model Number(s): C-750  
(42 IN. L.L., 17.99 GAL/IN., 48 IN. MAX. DEPTH OF BURY, 362 G.P.D. WHEN  
USED AS A SEPTIC TANK BASED ON A 3 YR. SERVICE INTERVAL FOR  
RESIDENTIAL WASTEWATER; TANK DIMENSIONS (OD) = 80 IN. L X 66 IN.  
W X 59 IN. H]  
Product File No: 20150222

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters SPS 382 through 384, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. **This approval is valid until the end of August 2020.**

This approval supersedes the approval issued on 8/05/2010 under product file number 20100315.

This approval is contingent upon compliance with the following stipulation(s):

- This product is approved to use a four-inch opening in access cover.
- This tank must be designed to withstand the pressures to which it will be subjected.
- The manufacturer must keep at the manufacturing plant a set of plans and specifications bearing the department's stamp of approval. The plans and specifications must be open to inspection by an authorized representative of the department.
- When this product receives wastewater from dwellings and is used as a septic tank, it will produce an effluent quality with a maximum monthly average value for BOD5 greater than 30 mg/L but less than or equal to 220 mg/L, TSS greater than 30 mg/L but less than or equal to 150 mg/L and F.O.G. less than or equal to 30 mg/L.
- Bedding: Tanks must be placed on soils capable of bearing the weight of tank and its contents, when full. Soft soils or bedrock must have 3 inches of tamped material, sand or gravel, 100% of which passes ½ -inch screen.

Identification Numbers
<b>Transaction ID No. 2591175</b>
<b>Site ID No.</b>
Please refer to both identification numbers, above, in all correspondence with the agency.

- Backfill: Fill must contain no stones or debris larger than 3 inches in diameter. Place backfill in uniform layer no larger than 24 inches

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Glen Jones, M.S.  
POWTS Product Reviewer  
phone: (608) 267-5265  
fax: (608) 267-9723  
email: glen.jones@wi.gov

The DSPS is committed to service excellence. Visit our survey at:

[www.surveymonkey.com/s/dspsiscustomersatisfaction](http://www.surveymonkey.com/s/dspsiscustomersatisfaction)